

STEAM PRESSURE REDUCING VALVE SCHEDULE								
MARK	LOCATION	SYSTEM AND/OR SERVICE	QUANTITY	REQUIRED CAPACITY	MAX FLOW WIDE OPEN VALVE	PRESSURE		NOTES
				LBS/HR	LBS/HR	IN PSIG	OUT PSIG	
2837	2-BM 129	SPD	1	4,935	5,810	95	55	
PRV #3/2591	2-BM 107	AUDITORIUM	1	2,940	3,460	95	25	
PRV #2	2-BM 103	HEAT	1	5,146	6,055	95	25	
PRV #1/3218	BLDG 3	HEAT	1	2,070	2,420	95	25	1:
PRV #3/2922	BLDG 4	HEAT	1	2,070	2,420	95	25	2:
3020	BLDG 6/8	HEAT	1	2,070	2,420	95	25	3:
3109	BLDG 10/12	HEAT	1	2,070	2,420	95	25	3:
422	BLDG 13/15	HEAT	1	2,070	2,420	95	25	3:
3184	BLDG 14/16	HEAT	1	2,070	2,420	95	25	3:
NOTES								
1. LOCATED IN STEAM AREA AT BASEMENT CORRIDORS TO SOUTH-EAST.								
2. LOCATED IN STEAM AREA AT BASEMENT CORRIDORS TO SOUTH-WEST.								
3. LOCATED IN BASEMENT STEAM ROOM AT JUNCTION AT BUILDINGS.								

CONDENSATE RETURN PUMPS											
MARK	MANUFACTURER	MODEL	LOCATION	SERVES	CONDENSATE FLOW RATE (GPM)	MOTIVE PRESSURE (PSIG)	RECEIVER	INLET PIPE SIZE (IN)	OUTLET PIPE SIZE (IN)	MOTIVE PIPE SIZE (IN)	NOTES
PPP-1	SPIRAX SARCO	APT-14	BLDG 2 BM103	2 WH-1	5.0	30	NONE	1 1/2"	1"	1/2"	1:
PPP-2	SPIRAX SARCO	APT-14	BLDG 2 BM103	2 WH-2	4.0	30	NONE	1 1/2"	1"	1/2"	1:
PPP-3	SPIRAX SARCO	APT-14	BLDG 2 BM103	2 WH-3	1.0	30	NONE	1 1/2"	1"	1/2"	1:
PPP-4	SPIRAX SARCO	APT-14	BLDG 3 MECH	3 WH-1	2.5	30	NONE	1 1/2"	1"	1/2"	1:
PPP-5	SPIRAX SARCO	APT-14	BLDG 4 MECH	4 WH-1	2.0	30	NONE	1 1/2"	1"	1/2"	1:
PPP-6	SPIRAX SARCO	APT-14	BLDG 6 MECH	6 WH-1	4.0	30	NONE	1 1/2"	1"	1/2"	1:
PPP-7	SPIRAX SARCO	APT-14	BLDG 11 BM117	11 WH-1	2.0	30	NONE	1 1/2"	1"	1/2"	1:
PPP-8	SPIRAX SARCO	APT-14	BLDG 12 MECH	12 WH-1	7.5	30	NONE	1 1/2"	1"	1/2"	1:
PPP-9	SPIRAX SARCO	APT-14	BLDG 16 MECH	14 WH-1	3.0	30	NONE	1 1/2"	1"	1/2"	1:
PPP-10	SPIRAX SARCO	APT-14	BLDG 19 MECH	19 WH-1	4.2	30	NONE	1 1/2"	1"	1/2"	1:
215	SPIRAX SARCO	PTC 2x2	BLDG 12 BM103	REPLACEMENT	REPLACEMENT	80	EXISTING	2"	2"	3/4"	2:
NOTES											
1. NEW AUTOMATIC PUMP TRAP (NOT A REPLACEMENT) TO SERVE EXISTING AERCO DOMESTIC WATER HEATER.											
2. REPLACEMENT OF EXISTING PUMP. REUSE EXISTING RECEIVER.											


GENERAL NOTES

- THESE MECHANICAL DRAWINGS ARE DIAGRAMMATIC ONLY AND ARE NOT TO BE SCALED. THE CONTRACTOR SHALL VISIT THE JOB SITE BEFORE WORK BEGINS TO VERIFY ALL DIMENSIONS. NOTIFY THE ENGINEER OF ANY CONFLICTS.
- COORDINATE PIPE ROUTING AND EQUIPMENT LOCATIONS WITH PLUMBING AND ELECTRICAL INSTALLATIONS AND WITH BUILDING STRUCTURAL MEMBERS. OFFSET PIPE AND SHIFT EQUIPMENT AS REQUIRED TO AVOID CONFLICTS.
- SUPPORT ALL PIPING, AND EQUIPMENT FROM PRIMARY BUILDING STRUCTURAL MEMBERS. PROVIDE ADDITIONAL STRUCTURAL MEMBERS WHERE NECESSARY TO ACCOMPLISH THIS REQUIREMENT.
- EQUIPMENT INDICATED TO BE REMOVED SHALL BE REMOVED FROM THE PROJECT SITE IN ITS ENTIRETY INCLUDING ALL HANGERS, ELECTRICAL CONDUIT, WIRING, ELECTRICAL JUNCTION BOXES, PIPING, CONTROLS AND ACCESSORIES RENDERED USELESS OR ABANDONED BY THE REMOVAL OF THE INDICATED EQUIPMENT.
- PAINT AND IDENTIFY ALL NEW PIPING, VALVES, AND EQUIPMENT, INCLUDING CONTROL COMPONENTS PER SPECIFICATIONS. ALL NEW PIPING INSULATION SHALL BE MARKED AND IDENTIFIED WITH SERVICE TYPE, SERVICE PRESSURE WHERE APPLICABLE, AND DIRECTION OF FLOW.


STEAM PRESSURE RELIEF VALVE SCHEDULE

MARK	LOCATION	SYSTEM AND/OR SERVICE	MINIMUM CAPACITY	SET PRESSURE	NOTES
			LBS/HR	PSIG	
2837	2-BM 129	SPD	5,810	60	
PRV #3/2591	2-BM 107	AUDITORIUM	3,460	30	
PRV #2	2-BM 103	HEAT	6,055	30	
PRV #1/3218	BLDG 3	HEAT	2,420	30	1:
PRV #3/2922	BLDG 4	HEAT	2,420	30	2:
3020	BLDG 6/8	HEAT	2,420	30	3:
3109	BLDG 10/12	HEAT	2,420	30	3:
422	BLDG 13/15	HEAT	2,420	30	3:
3184	BLDG 14/16	HEAT	2,420	30	3:
NOTES					
1. LOCATED IN STEAM AREA AT BASEMENT CORRIDORS TO SOUTH-EAST.					
2. LOCATED IN STEAM AREA AT BASEMENT CORRIDORS TO SOUTH-WEST.					
3. LOCATED IN BASEMENT STEAM ROOM AT JUNCTION AT BUILDINGS.					


DRAWING DESIGNATIONS




SECTION INDICATOR



PIPING DESIGNATIONS





VALVE/TRAP DESIGNATIONS



LEGEND

AFF.	ABOVE FINISHED FLOOR
B.E.	BOTTOM ELEVATION
CAP.	CAPACITY
"F"	DEGREES FAHRENHEIT
EFF.	EFFICIENCY
FT.	FEET
GAL.	GALLON(S)
G.P.M.	GALLONS PER MINUTE
IN.	INCHES
IN. W.G. / FT. W.G.	INCHES WATER GAUGE / FEET WATER GAUGE
MNFR	MANUFACTURER
MAX.	MAXIMUM
MBH	BTUH x 1000
MIN.	MINIMUM
N.C.	NORMALLY CLOSED
N.O.	NORMALLY OPEN
LB/HR	POUNDS PER HOUR
P.S.I.G.	POUNDS PER SQUARE INCH - GAUGE
PRESS.	PRESSURE
---	NEW PIPE OR EQUIPMENT
---	EXISTING PIPE OR EQUIPMENT
----	DEMOLISH PIPE OR EQUIPMENT
---	CONCENTRIC PIPE REDUCER
---	ECCENTRIC PIPE REDUCER
---	PITCH OF PIPE ARROW SHOWS DIRECTION OF DROP
---	INTERMEDIATE ANCHOR
---	MAIN ANCHOR
---	EXPANSION JOINT
---	EXPANSION LOOP
---	FLEXIBLE CONNECTOR
---	VERTICAL PIPE TEE
---	TOP CONNECTION FITTING
---	VERTICAL PIPE
---	PIPE DROP
---	STRAINER ("Y" TYPE)
---	GATE VALVE
---	GLOBE VALVE
---	CHECK VALVE
---	BALL VALVE
---	DIAPHRAGM OPERATED VALVE
---	REGULATOR VALVE
---	RELIEF VALVE
---	CONTROL VALVE TAG
---	CONTROL VALVE
---	VALVE IN THE VERTICAL
---	REDUCER
---	TRAP
---	PUMP TRAP
---	UNIT HEATER
---	PRESSURE INDICATOR
---	TEMPERATURE INDICATOR
---	DIRECTION OF FLOW
---	PIPE COUPLING
---	PIPE CAP
---	WALL IN PLAN
---	FLOOR OR WALL IN ISOMETRIC
---	DRAIN

Revisions	Date	 APPLIED ENGINEERING SOLUTIONS 440 Martin Luther King, Jr. Blvd., Suite 401 Macon, Georgia 31201 (478) 314-1270 www.aes-pe.com				Drawing Title MECHANICAL LEGEND, GENERAL NOTES AND SCHEDULES	Project Title STEAM AND CONDENSATE PIPING SYSTEM STUDY	Date JUNE 22, 2012	Veterans Administration		
							Building Number	Checked CAMEJO		Drawn WILLIAMSON	Project No. 557-10-109
						FINAL SUBMITTAL	Location CARL VINSON VA MEDICAL CENTER DUBLIN, GEORGIA				DRAWING NO. I-1.02 Dwg. 2 of 87